


NOTES:

- 1.) AERATOR MODELS 560-S AND 660-FP OR HIGHER MODEL NUMBERS MUST BE USED.
- 2.) THIS COVERED ACCESS MUST BE DEVELOPED TO 6"-12" BELOW GRADE FOR NSF INSTALLATIONS.
- 3.) RISER CASTING EXTENSION USED ONLY IF FIRST CASTING DOES NOT REACH GRADE.
- 4.) PLANTS WHICH DO NOT USE A PLASTIC INLET TEE ASSEMBLY IN THE PRETREATMENT COMPARTMENT MAY USE AN OPTIONAL CAST-IN INLET TEE.
- 5.) PLANTS WHICH DO NOT HAVE A CAST-IN TRANSFER TEE IN THE PRETREATMENT COMPARTMENT WILL USE A PLASTIC TRANSFER TEE ASSEMBLY.
- 6.) PLANTS WHICH DO NOT HAVE A CAST-IN OUTLET TEE IN THE SETTLING COMPARTMENT WILL USE A PLASTIC OUTLET TEE ASSEMBLY.

 JET INC. CLEVELAND, OHIO	DRAWN BY: R. P. T. APPROVED BY:	DATE: 2-3-93 DATE:
	MATERIAL:	
TITLE: HOME PLANT TANK AND COMPONENT PARTS INSTALLATION	SCALE: NONE UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS IN INCHES	
USED ON: MODEL J-353 A D	DRAWING NUMBER: ART-399	